CODE/ADDENDA _____ APPROVED _____
RELEASED FOR PRODUCTION
Q.C. _____ DATE _____





FIND NO.	NPT SIZE
F1	2
F2	1
F3	1/2
F4	1/4
F5	1-1/2

SYM	DATE	BY	REVISION	APP
A		EGB		TA
B		JC		JC
C		JC		

NOTES

SPECIFICATIONS

O.D.: 30 LGTH: 72
MAWP: 200 PSI @ 400° F
RT MDMT- F@ PSI
EXMT:
X-RAY:
CRN# --

GAL: 200 SA: 51 ft²
WT: 450 # CU.FT: 27
CORR ALW: SH HD
CODE: ASME / NB
PER DATE OF DWG/LAST REV

WELD DETAILS M-1932
STD. TOLERANCES (UNLESS OTHERWISE NOTED) M-2461

MANCHESTER TANK

Q:\3000

VERTICAL AIR RECIEVER
200 GALLON

DRAWN BY	DATE	SCALE: NONE
LB		
APP. BY	DATE	DRAWING NO.
AS		302426